



FRANKLIN TOWNSHIP SEWERAGE AUTHORITY

70 Commerce Drive, Somerset, NJ 08873-3470

Tel: (732) 873-2121 • Fax: (732) 873-2038 • www.ftsa-nj.org

December 1st, 2020

Project Applicant: 3 Ronson, LLC
Project Location: 1165 State Hwy #27, Somerset
Block: 88.01, L: 43
Docket #: PLN-20-00012

The applicant is proposing to construct a 2,907 square feet Dunkin Donuts. The Authority provided a Will Serve Letter on 10/19/2020 to confirm sewer capacity. The following are preliminary items required by the Authority (please submit all items on a CD excluding checks):

- 1) **FTSA Application:** Application Fee of \$50.00
- 2) **Escrow Deposit:** Minimum deposit of \$500.00
- 3) **Construction Plans:**
 - Attach all three (3) sheets of FTSA Standard Details to the plan.
 - Include the length, slope, material, inverts, cleanouts, profiles, and ownership of the sanitary sewers.
- 4) **Sealed Engineers Report:** Summary of proposal, existing flow conditions, proposed sewage quality (domestic, commercial, or industrial), proposed average flow calculation, proposed peak flow calculation, sewage velocity calculation, pipe capacity analysis, clarify if any existing sanitary sewer laterals are being used, etc.
- 5) **Sealed Sanitary Sewer Construction Specs:** Please reference Appendix C of the Authority Rates, Rules, and Regulations.
- 6) **Sealed Sanitary Sewer Cost Estimate:** Please reference Appendix F of the Authority Rates, Rules, and Regulations.

The nature of this letter is for informational purposes and shall not constitute board approval of a Sanitary Sewer Application.

Thank you.

Christian Santiago
Staff Engineer
Franklin Township Sewerage Authority