

SANITARY FLOW REPORT

FOR


SAINT SHARBEL MARONITE CHURCH

LOTS 1, 2, 3, 4, 5 AND 6 IN BLOCK 261

526 EASTON AVENUE

TOWNSHIP OF FRANKLIN, SOMERSET COUNTY

NEW JERSEY



CONSULTING ENGINEERS AND DESIGN PROFESSIONALS

205 ROUTE 9 NORTH, FREEHOLD, NJ 07728

TEL: 732-303-7992 ♦ FAX: 732-303-7993

WWW.REMOENGINEERING.COM

MARC A. REMO, P.E., P.P., C.M.E.

NJ PROFESSIONAL ENGINEER LIC. NO. 37145

NJ PROFESSIONAL PLANNER LIC. NO. 5195

DATE PREPARED: 3/1/2021

FranklinTwp526EastonAveSanFlowRpt3-1-21

PROJECTED SEWAGE FLOW COMPUTATIONS

THE PROJECTED FLOWS GENERATED FROM THE PROPOSED DEVELOPMENT TO BE SERVED BY THE EXISTING SANITARY SEWER ARE AS FOLLOWS:

ESTIMATED DAILY AVERAGE FLOW (Q)

ESTIMATED FLOW FOR CHURCHES = 3 GPD/SEAT
(N.J.A.C. 7:14A-23.3)

NUMBER OF SEATS = 300

$Q = 3 \text{ GPD/SEAT} \times 300 \text{ SEATS} = \mathbf{900 \text{ GPD}}$

ESTIMATED PEAK FLOW (Qp)

$Q_p = 3 \times \text{ESTIMATED DAILY AVERAGE FLOW}$

$Q_p = 3 \times 900 \text{ GPD} = \mathbf{2,700 \text{ GPD}}$

$Q_p = 2,700 \text{ GPD} \times .1 \text{ DAY/24 HRS} \times 1 \text{ HR/60 MIN} = 1.88 \text{ GPM}$

$Q_p = 1.88 \text{ GAL/MIN} \times 1 \text{ CFS/448.8 GAL/MIN} = 0.004189 \text{ CFS}$

MAXIMUM DESIGN FLOW (Qd)

$Q_d = \text{ESTIMATED PEAK FLOW IN MGD}$

$Q_d = 2,700 \text{ GPD} \times 1 \text{ MGD/1,000,000 GPD} = \mathbf{0.002700 \text{ MGD}}$

APPENDIX 1

PROJECTED FLOW CRITERIA CHART

N.J.A.C. 7:14A - 23.3 Projected Flow Criteria

The values specified below are to be used in computing the projected flow to wastewater conveyance and treatment facilities. The specific measurement unit listed for each category must be used as the basis for the projected flow. No additional provisions for inflow and infiltration are required. Flow for facilities that have combined uses must be determined by the summation of all appropriate projected flow values for each use. In the event that a facility is not covered by the table below, the applicant must propose the projected flow based upon operation of similar facilities or best professional judgment.

Type of Establishment	Measurement Unit	Gallons Per Day	Type of Establishment	Measurement Unit	Gallons Per Day
Residential Dwellings (single family home, duplex units, townhouses, condominiums, apartments)			Institutions (includes staff)		
1 bedroom unit	Per Dwelling	150	Hospitals	Bed	175
2 bedroom unit	Per Dwelling	225	Other institutions	Bed	125
3 bedroom unit or larger	Per Dwelling	300	Schools (includes staff)		
Transit dwelling units			No shower or cafeteria	Student	10
Hotels	Bedroom	75	With cafeteria	Student	15
Lodging houses and tourist homes	Bedroom	60	With cafeteria and showers	Student	20
Motels and tourist cabins	Bedroom	60	With cafeteria, showers and laboratories	Student	25
Boarding houses (max. permitted occupancy)	Boarder	50	Boarding	Student	75
Camps			Automobile service stations		
Campground/mobile rec. vehicle/tent	Site	100	Service bays	per bay	50
Parked mobile trailer site	Site	200	Filling position	per filling position	125
Children's camps	Bed	50	Mini-market	Sq. Ft.	0.100
Labor camps	Bed	40	Miscellaneous		
Day camps--no meals	Person	15	Office buildings (gross area)	Sq. Ft.	0.100
Restaurants (including washrooms and turnover)			Stores and shopping centers (gross area)	Sq. Ft.	0.100
Average restaurant	Seat	35	Factories/warehouses (add process water) with showers, (add process water)	Employee	25
Bar/cocktail lounges	Seat	20	Laundromats	Employee	40
Fast food restaurant	Seat	15	Bowling alleys	Machine	580
24 hour service restaurant	Seat	50	Picnic Parks (restrooms only)	Alley	200
Curb service/drive-in restaurant	Car space	50	Picnic Parks with showers	Person	10
Clubs			Fairgrounds (based upon average attendance)	Person	15
Residential	Member	75	Assembly halls	Person	5
Nonresidential	Member	35	Airports (based on passenger use)	Seat	3
Racquet club	court per hour	80	Churches (worship area only)	Passenger	3
Bathroom with shower	Person	25	Theater (indoor)	Seat	3
Bathroom without shower	Person	10	Dinner theater	Seat	20
			Catering/Banquet Hall	Person	20
			Sports stadium	Seat	3
			Visitor Center	Visitor	5