

ENVIRONMENTAL COMMISSION

SafStor PLN-21-000103

Recommendations. Solar Cells on roof or mounted on poles in parking area. Electric Car charger. Available to visitors.

Pervious paving for parking areas.

There is a concern about exterior lighting. This property adjoins Somerset Run. Some of the buildings are fairly close to the applicant unit. May be a concern, perhaps limiting night time lighting. We note the LEDs (should be full cut off) for exterior but they still may reach adjacent residents.

Tree planting is in line with Township Ordinance

Question as to Retention basin. Does it conform with new regulations.?

Paul Walitsky

Vice Chair

Franklin Township Environmental Commission

09/09/2021