



Water Quality Report 2014

Township of Franklin

English

This report contains important information about your drinking water. If you do not understand it, please have someone translate it for you.

Spanish

Este informe contiene información muy importante sobre su agua de beber. Tradúzcalo ó hable con alguien que lo entienda bien.

Gujarati

આ અહેવાલ માં તમારા પીવાના પાણી વિષે
જાગ્રત્વ ની જાળવણી જાપવા માં આવી છે.
એનો અર્થુચાલ કરો જોવા જેને સમજાવો પડશે
તેમ તેમો આખે ઘાત કરો



Dear Water Consumer:

This 2014 Water Quality Report is an annual report to all water consumers on the quality of water provided by the Township of Franklin. This report meets the Federal Safe Drinking Water Act requirements for Consumer Confidence Reports.

This 2014 Water Quality report provides our customers with information on the sources of our drinking water, our water system, applicable health information and the concentrations of detected contaminants with a comparison to water quality regulations.

In addition to this water quality report, a Tier 3 public notification is also attached. We are required to take minimum 50 Total Coliform monitoring samples each month. In September 2014, we took 49 samples due to a miscommunication with our lab.

The Township of Franklin is committed to providing our customers with high quality drinking water and information about the drinking water that we provide. Our constant goal is to provide you with a safe and dependable supply of drinking water.

If you would like additional information or if you have any questions concerning this report, feel free to call the Township Water Department at 732.249.7800. You can also call the EPA Safe Drinking Water Hotline at 800.426.4791 for further information.

Sincerely,
Howard Chi
Licensed Operator
Township of Franklin

Annual Drinking Water Quality Report

Franklin Township

For the Year 2015, Results from the Year 2014

We are pleased to present to you this year's Annual Drinking Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you. Our constant goal is to provide you with a safe and dependable supply of drinking water. We are committed to ensuring the quality of your water. Our water sources are surface and well water from New Jersey American Water Co., the Township of South Brunswick Water Department, and the New Brunswick Water Department. The New Jersey Department of Environmental Protection (NJDEP) has completed and issued the Source Water Assessment Report and Summary for all of these public water systems, which are available at www.state.nj.us/dep/swap or by contacting NJDEP's Bureau of Safe Drinking Water at (609) 292-5550. You may also contact your public water system to obtain information regarding these Source Water Assessments.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

The Franklin Township Water Department and all of our suppliers routinely monitor for contaminants in your drinking water according to Federal and State laws. The tables show the results of ours and our suppliers monitoring for the period of January 1st to December 31st, 2014. The state allows all of us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative, are more than one year old.

Franklin Township Water Department PWS ID# NJ1808001 Year 2014 Test Results						
Contaminant	Violation Y/N	Level Detected	Units of Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants:						
Copper Result at 90 th Percentile Test results Yr. 2013	N	0.4 No samples exceeded the action level	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits
Lead Result at 90 th Percentile Test results Yr. 2013	N	7 2 samples out of 32 exceeded the action level	ppb	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits
Microbiological Contaminants:						
Total coliform Bacteria ²	Y	1 positive routine sample in May, 2 in June, 1 in July and 2 positive repeat samples in May.		0	5% of monthly samples	Naturally present in the environment
Disinfection Byproducts¹:						
TTHM Total Trihalomethanes	N	Range = 5 - 54 Highest LRAA = 29	ppb	N/A	80	By-product of drinking water disinfection
HAA5 Haloacetic Acids	N	Range = 1 - 41 Highest LRAA = 13	ppb	N/A	60	By-product of drinking water disinfection
Regulated Disinfectants		Level Detected	MRDL		MRDLG	
Chlorine		Average = 0.9 ppm	4.0 ppm		4.0 ppm	

Unregulated Contaminant Monitoring³ (Franklin Township Water)

Contaminant	Level Detected	Unit of Measurement	Likely Source
Chromium (Total)	Range = ND - 0.48; Highest detect = 0.48	ug/l	Erosion of natural deposits
Vanadium	Range = ND - 0.37; Highest detect = 0.37	ug/l	Erosion of natural deposits
Chromium VI	Range = 0.066 - 0.16; Highest detect = 0.16	ug/l	Erosion of natural deposits
Chlorate	Range = 50 - 165; Highest detect = 165	ug/l	Erosion of natural deposits
Strontium	Range = 90 - 160; Highest detect = 160	ug/l	Erosion of natural deposits

1. HAA5 and TTHM compliance is based on a Locational Running Annual Average (LRAA), calculated at each monitoring location. The LRAA calculation is based on four completed quarters of monitoring results.

2. We collect a minimum of 50 total Coliform Bacteria samples each month. 5% of those samples are allowed have positive results. All repeat - confirmation samples were negative, except in May when we had two (2) positive repeat samples. All subsequent samples were negative. During September 2014, we collected 49 total Coliform Bacteria samples for that month which is 1 sample less than the required. This error was caused by a miscommunication with our laboratory. As result of this error, a tier 3 violation is issued by the NJDEP. Total Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present.

3. Franklin Township Water participated in the Unregulated Contaminant Monitoring Rule. Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted.

Lead: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Franklin Township Water Department and all of its drinking water suppliers are responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap

for 30 second to 2 minutes before using water for drinking and cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water hotline or at <http://www.epa.gov/safewater/lead>.

New Jersey American Water Company (Raritan System)						
PWS ID# NJ2004002						
Year 2014 Test Results						
Contaminant	Violation Y/N	Level Detected	Units of Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants:						
Copper Result at 90 th Percentile Test results Yr. 2013	N	0.4 No samples out exceeded the action level	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits
Fluoride	N	Range = ND – 0.9 Highest detect = 0.9	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Lead Result at 90 th Percentile Test results Yr. 2013	N	3 1 sample out of 51 exceeded the action level	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Nitrate (as Nitrogen)	N	Range = 0.6 – 2.0 Highest detect = 2.0	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Disinfection Byproducts:						
TTHM Total Trihalomethanes	N	Highest LRAA = 47	ppb	N/A	80	By-product of drinking water disinfection
HAA5 Haloacetic Acids	N	Highest LRAA = 32	ppb	N/A	60	By-product of drinking water disinfection
Bromate	N	Range = ND – 6 Highest detect = 6	ppb	0	10	By-product of drinking water disinfection
Microbiological Contaminants						
Total coliform Bacteria	N	Highest Percentage = 0.7		0	5% of monthly samples	Naturally present in the environment
Turbidity	N	100% < 0.3 Highest detect = 0.2	NTU	N/A	TT <0.3 in 98% of monthly samples	Soil runoff
Total Organic Carbon (%)	N	Range = 1.0 – 3.2 Highest detect = 3.2	ppm	NA	TT = % removal	Naturally present in the environment
Regulated Disinfectants		Level Detected		MRDL		MRDLG
Chloramines		Range = 0.5 – 1.3 ppm		4.0 ppm		4.0 ppm
Secondary Contaminant		Level Detected	Units of Measurement			RUL
Sodium		Range = 28 - 97	ppm			50

New Jersey American Water participated in the Unregulated Contaminant Monitoring Rule. Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted.

Unregulated Contaminant Monitoring

Contaminant	Level Detected	Units of Measurement	Likely source
Perfluorooctanoic Acid (PFOA)	Range = ND – 0.018	ppb	Man-made chemical used in the manufacture of fluoropolymers
Hexavalent Chromium	Range = ND – 0.1	ppb	Erosion of natural deposits. Discharges from steel and pulp mills.
N-nitrosopyrrolidine (NPYR)	Range = ND – 0.0033	ppb	Byproducts in chemical synthesis.

Perfluorooctanoic Acid (PFOA) is a man-made chemical used in the manufacture of fluoropolymers. With non-stick and stain-resistant properties, fluoropolymers have a wide application in common household products such as cookware, carpet and all-weather clothing. There is currently no regulatory limit established for PFOA in drinking water. However, in February 2007 the NJ Department of Environmental Protection (NJDEP) issued a preliminary guidance level of 0.04 ppb. In order to assist the NJDEP in assessing the occurrence of this substance in New Jersey, New Jersey American Water began to monitor for PFOA in some of its systems. We are sharing the results in this report because we want to educate our customers about the quality of their drinking water. The proactive approach reinforces our continuing commitment to protect public health and provide quality drinking water and reliable service. For more information on PFOA, contact NJDEP at 609-292-5550.

Hexavalent Chromium Major sources of hexavalent chromium (chromium-6) in drinking water are discharges from steel and pulp mills, and erosion of natural deposits of chromium-3. Hexavalent Chromium is not currently regulated as an individual substance. NJ American Water voluntarily performed this monitoring based on recommendations from the USEPA. For more information on Hexavalent Chromium (Chromium6), please visit NJ American website.

N-nitrosopyrrolidine (NPYR) Nitrosamines can form as intermediates and byproducts in chemical synthesis and manufacture of rubber, leather and plastics; can form spontaneously by reaction of precursor amines with nitrosating agents (nitrate and related compounds), or by action of nitrate-reducing bacteria. Foods such as bacon and malt beverages can contain nitrosamines; there is also evidence that they form in the upper GI tract.

Sodium: New Jersey American Water exceeded the secondary Recommended Upper Limit for Sodium. For healthy individuals the sodium intake from water is not important, because a much greater intake of sodium takes place from salt in the diet. However sodium levels above the Recommended Upper Limit (RUL) may be of concern to individuals on a sodium restricted diet.

City of New Brunswick Water Department PWS ID# NJ1214001 Year 2014 Test Results						
Contaminant	Violation Y/N	Level Detected	Units of Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants:						
Barium	N	0.04	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Chromium	N	0.5	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
Copper Result at 90 th Percentile	N	0.02 No samples out exceeded the action level	Ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits
Fluoride	N	0.05	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Lead Result at 90 th Percentile	N	7.7 2 samples out of 32 exceeded the action level	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Nickel	N	1.06	ppb	N/A	N/A	Erosion of natural deposits
Nitrate (as Nitrogen)	N	0.7	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Microbiological Contaminants:						
Turbidity	N	Highest detect = 0.69	NTU	N/A	95 % of samples < 0.3 NTU	Soil runoff, naturally present in the environment.
Disinfection Byproducts:						
TTHM Total Trihalomethanes	N	Highest LRAA = 45	ppb	N/A	80	By-product of drinking water disinfection
HAA5 Haloacetic Acids	N	Highest LRAA = 73	ppb	N/A	60	By-product of drinking water disinfection
Regulated Disinfectants		Level Detected		MRDL		MRDLG
Chlorine		Average = 1.2 ppm		4.0 ppm		4.0 ppm

HAA5 and TTHM compliance is based on a Locational Running Annual Average (LRAA), calculated at each monitoring location. The LRAA calculation is based on four completed quarters of monitoring results.

The City of New Brunswick Water Department participated in the Unregulated Contaminant Monitoring Rule. Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted.

City of New Brunswick Water Department

Unregulated Contaminant Monitoring

Contaminant	Level Detected	Units of Measurement	Likely source
Perfluoro butanic Acid (PFBA)	0.011	ppb	Used in the manufacture of fluoropolymers
Perfluoro octane sulfonic Acid (PFOS)	0.0072	ppb	Used in the manufacture of fluoropolymers
Perfluoro octanic Acid (PFOA)	0.008	ppb	Used in the manufacture of fluoropolymers
Strontium	Range = 84 – 95 Highest detect = 95	ppb	Erosion of natural deposits
Vanadium	Range = ND – 0.70 Highest detect = 0.44	ppb	Erosion of natural deposits
Chlorate	Range = 84 - 180 Highest detect = 180	ppb	Erosion of natural deposits
Chromium (total)	Range = ND – 0.47 Highest detect = 0.47	ppb	Erosion of natural deposits

South Brunswick Township Water Department PWS ID# NJ1221004 Year 2014 Test Results						
Contaminant	Violation Y/N	Level Detected	Units of Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants:						
Barium	N	Range = 0.04 – 0.12 Highest detect = 0.12	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Fluoride	N	Range = ND – 0.9 Highest detect = 0.9	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Nitrate (as Nitrogen)	N	Range = 1.4 – 2.4 Highest detect = 2.4	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Copper Result at 90 th Percentile	N	0.05 No samples exceeded the action level	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits
Lead Result at 90 th Percentile	N	2 No samples exceeded the action level	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Radioactive Contaminants:						
Alpha emitters	N	Range = 1.7 – 7.3 Highest detect = 7.3	pCi/l	0	15	Erosion of natural deposits
Combined Radium 228 & 226	N	Range = 0.2 – 3.9 Highest detect = 3.9	pCi/l	0	5	Erosion of natural deposits
Disinfection Byproducts:						
TTHM Total Trihalomethanes	N	Range = 6 - 59 Highest LRAA = 42	ppb	N/A	80	By-product of drinking water disinfection
HAA5 Haloacetic Acids	N	Range = ND - 33 Highest LRAA = 27	ppb	N/A	60	By-product of drinking water disinfection
Microbiological Contaminants						
Total coliform Bacteria	N	2 positive samples out of 62 in July		0	5% of monthly samples	Naturally present in the environment
Regulated Disinfectants		Level Detected		MRDL		MRDLG
Chlorine		Average = 0.4 ppm		4.0 ppm		4.0 ppm

HAA5 and TTHM compliance is based on a Locational Running Annual Average (LRAA), calculated at each monitoring location. The LRAA calculation is based on four completed quarters of monitoring results.

Secondary Contaminant	Level Detected	Units of Measurement	RUL
Manganese	Range = 2 - 146	ppb	50

The South Brunswick Township Water Department exceeded the secondary Recommended Upper Limit (RUL) for manganese which is based on staining of laundry. Manganese is an essential nutrient, and toxicity is not expected from levels which would be encountered in drinking water. Manganese is a naturally occurring element in soil, groundwater, and some surface waters. Manganese is considered harmless to health, however, they may give water an off taste or color, cause splotchy yellow stains on laundry, and clog water systems.

The South Brunswick Township Water Department participated in the Unregulated Contaminant Monitoring Rule. Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted.

Unregulated Contaminant Monitoring

Contaminant	Level Detected	Units of Measurement	Likely source
Perfluorooctanoic Acid (PFOA)	Range = ND – 0.018	ppb	Man-made chemical used in the manufacture of fluoropolymers
Hexavalent Chromium	Range = ND – 0.1	ppb	Erosion of natural deposits. Discharges from steel and pulp mills.
N-nitrosopyrrolidine (NPYR)	Range = ND – 0.0033	ppb	Byproducts in chemical synthesis.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can, also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

DEFINITIONS

In the following table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Non-Detects (ND) - laboratory analysis indicates that the constituent is not present.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

Nephelometric Turbidity Unit (NTU) - nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal -The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Secondary Contaminant- Substances that do not have an impact on health. Secondary Contaminants affect aesthetic qualities such as odor, taste or appearance. Secondary standards are recommendations, not mandates.

Recommended Upper Limit (RUL) – Recommended maximum concentration of secondary contaminants. These reflect aesthetic qualities such as odor, taste or appearance. RUL's are recommendations, not mandates.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant, below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination

Total Organic Carbon – Total Organ Carbon (TOC) has no health effects. However, TOC provides a medium for the formation of disinfection byproducts. The *Treatment Technique* for TOC requires that 35% - 45% of the TOC in the raw water is removed through the treatment processes.

Turbidity – Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium microbial growth. Turbidity is measured as an indication of the effectiveness of the filtration process. The *Treatment Technique* for turbidity requires that no individual sample exceeds 1 NTU and 95% of the samples collected during the month must be less than 0.3 NTU.

If you have any questions about this report or concerning your water utility, please contact the Franklin Township Public Works Department at 732-249-7800 ext. 6414. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled Town Council meetings.

We all work hard to provide top quality drinking water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Monitoring Requirements Not Met for Franklin Township Water
40 Churchill Avenue, Somerset, NJ 08873

Our water system violated a drinking water standard over the past year. Even though these were not emergencies, as our customers, you have a right to know what happened and what we did to correct these situations.

We are required to monitor your drinking water for Total Coliform Bacteria on a regular basis. Results of the regular monitoring are an indicator of whether or not our drinking water meets health standards. In September 2014, we collected 49 samples and tested for Total Coliform Bacteria. Under Total Coliform Rule (TCR), minimum of 50 samples should be collected each month. The missing of one samples is an error that caused by the miscommunication with our lab. We have worked with our lab to reinforce the sample collection protocol to prevent this type error in the future.

What should I do?

There is nothing you need to do at this time.

The table below lists the contaminant(s) we did not properly tested during the September 2014, how often we are supposed to sample for this contaminant and how many samples we are supposed to take, how many samples we took, and when samples should have been taken.

Contaminant	Required sampling frequency	Number of samples taken	When all samples should have been taken	When samples were or will be taken
Total Coliform Bacteria*	Monthly	Total of 49 samples were collected in September 2014	Minimum 50 monitoring samples should be collected each month	During the month

What happened? What is being done?

We collected 49 samples during the month of September 2014 while minimum of 50 samples are required. This error is caused by our miscommunication with testing lab. To avoid this type of error in the future, we revised our sample collection protocols and collect extra samples for each month.

For more information, please contact Howard Chi of Franklin Township Water at 732-249-7800.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

Public Water System ID#: NJ1808001. Date distributed: 6/25/2015

* People with severely compromised immune systems, infants, and some elderly may be at increased risk if exposed to Total Coliform bacteria. These people should seek advice about drinking water from their health care providers. General guidelines on ways to lessen the risk of infection by microbes are available from EPA's Safe Drinking Water Hotline at 1 (800) 426-4791.

Township of Franklin
475 DeMott Lane
Somerset, NJ 08873-2737

PRSRT STD
U. S. Postage
PAID
New Brunswick, NJ
08901
Permit No. 1265

Postal Patron

Water Quality Report 2014